

County of Riverside DEPARTMENT OF ENVIRONMENTAL HEALTH

For general information call: 1-888-722-4234 www.rivcoeh.org

FACILITY NAME					DATE	TIME IN	TIME OUT
Temecula Pizza Factory					10/24/2019	3:50 PM	4:30 PM
LOCATION						RE-INSPECTION DATE	
31725 Temecula Pkwy Ste.D, Temecula, CA 92592						Next Routine	
PERMIT HOLDER					E-MAIL		
PF Industries LLC					Not Specified		
EXPIRATION DATE:	SERVICE	FACILITY PHONE	PE	DISTRICT	INSPECTOR NAME		
06/30/2020	Reopen Closed Facility	(951)303-8500	2621	0041	Philip Sinclair		
	Pkwy Ste.D, Temecu LLC EXPIRATION DATE:	A Pkwy Ste.D, Temecula, CA 92592 LC EXPIRATION DATE: SERVICE Report Closed Facility	a Pkwy Ste.D, Temecula, CA 92592 LLC EXPIRATION DATE: SERVICE Reopen Closed Facility FACILITY PHONE	a Pkwy Ste.D, Temecula, CA 92592 LLC EXPIRATION DATE: SERVICE FACILITY PHONE PE	a Pkwy Ste.D, Temecula, CA 92592 LLC EXPIRATION DATE: SERVICE FACILITY PHONE PE DISTRICT Reopen Closed Facility	Za Factory 10/24/2019 A Pkwy Ste.D, Temecula, CA 92592 E-MAIL Not Specified EXPIRATION DATE: SERVICE Page Facility People Closed Facility People	Za Factory 10/24/2019 3:50 PM RE-INSPECTION DA Next Routine E-MAIL Not Specified EXPIRATION DATE: SERVICE Reopen Closed Facility Response Closed Facility

Inspector Observations:

Re-inspection conducted to verify that the hot water has been restored to the facility. Observed the hot water from all sinks inside the facility at 120F or greater (6 hand sinks, 1 preparation sink, 1 3-compartment sink, 1 janitorial sink). Inspector observed invoice for repair at time of inspection. Facility Closed sign removed. Facility has been re-opened and approved to operate.

Signature	
	Belef und
Breanna Hawkins	Philip Sinclair
Person in Charge	Environmental Health Specialist
10/24/2019	10/24/2019